Specifications

| Item | Specification | | |
|---|--|---|--|
| Type | Propane air mixer | | |
| Model | PA - 60 | | |
| Capacity | 60 m³/h (normal) (Propane air mixed gas) | | |
| Feeder gas requirement | Composition | LP gas containing 95% or more propane gas (20% or more liquid LP gas should be left in each cylinder) $1.5 \sim 15.6 \qquad \text{bar}$ | |
| Outlet pressure | | 15 ~ 25 mbar | |
| First stage regulator | Outlet pressure Capacity | $0.85 \sim 1.05$ bar $70 \text{ kg/h (LPG)} \times 2$ | |
| Venturi mixer 1/2 | Nozzle pressure | 0.8 ~ 1.0 bar | |
| | Nozzle diameter | $\phi5.05\!\pm\!0.03$ mm | |
| | Throat diameter | $\phi~7.70\pm0.03$ mm | |
| | Area ratio | $2.325 (2.280 \sim 2.371)$ | |
| Working pressure of open-close valve controller | Pressure of injection start | 50 ~ 70 mbar | |
| | Pressure of injection stop | 140 ~ 160 mbar | |
| Actuating pressure of safety valve | Shut-off pressure of abnormal negative pressure | | |
| | | -15 ± 5.0 mbar | |
| | Shut-off pressure of over pressure | | |
| | | 1.5 ± 0.2 bar | |
| | Shut-off pressure of under pressure | | |
| | | 0.5 ± 0.2 bar | |
| | Shut-off pressure of over pressure of cushion tank | | |
| | | 230±30 mbar | |
| Mixed gas | Total calorific value | 58.6 MJ/m³ (normal) | |
| | Accepted range | 56.30 ~ 59.58 MJ/m³ (normal) | |

| | From inlet connection to inlet of first stage regulator | | |
|--|---|----------|--|
| | 18 | bar | |
| | From outlet of first stage regulator to inlet of second stage | | |
| | regulator | | |
| Leakage test | 2.0 | bar | |
| S | At cover parts of shut-off valve | | |
| | 300 | mbar | |
| | At outlet of second stage regulator | inbai | |
| | | 1 | |
| | 42 | mbar | |
| | From inlet connection to inlet of first stage regulator | | |
| | 24 | bar | |
| | From outlet of first stage regulator to inlet of second stage | | |
| | regulator | | |
| Hydrostatic test | 3.0 | bar | |
| | At cover parts of shut-off valve | | |
| | 400 | mbar | |
| | | moar | |
| | At outlet of second stage regulator | | |
| | 42 | mbar | |
| Inlet connection | JIS 20K 20A Flange | | |
| Outlet connection | Rc 1 1/2 | | |
| External dimension | Width $2062 	imes 	ext{Depth}$ $1156.5 	imes 	ext{Height}$ 1 | 1732 mm | |
| Cushion tank | Inner volume Approx. 0.118 m³ ×2 | | |
| Working temperature | 17 10 | 000 | |
| | $-15 \sim 40$ °C | | |
| Product weight | Approx. 300 | kg | |
| Cushion tank Working temperature range | Inner volume Approx. 0.118 m^3 $-15 \sim 40$ | °×2 ℃ | |

APR. 4.2017

⊕ I·T·O Corporation

10-4 Hakodono-cho, Higashi-Osaka City, Japan TEL:072-981-3781 FAX:072-987-6590